


**PLAN**



**NOTES**

- PANEL AND PLATE TO BE FABRICATED FROM 3mm ALUMINIUM SHEETING.
- PANEL TO BE FOLDED PRIOR TO DELIVERY ON SITE.
- PANEL AND PLATE TO BE ADHERED TO LIMESTONE STRUCTURE USING SUITABLE COMPOUND TO ENSURE A PERMANENT FIXING.
- WALL SHALL BE CONSTRUCTED FROM RECONSTITUTED LIMESTONE BLOCKS OF SIZES 1000mm x 350mm x 350mm BUILT IN ACCORDANCE WITH DETAILS ON THIS DRAWING.
- REFER TO LANDSCAPE CONSULTANT'S DRAWINGS FOR LOCATION OF WALL.
- DENSITY OF RECONSTITUTED LIMESTONE SHALL BE A MINIMUM OF 1650kg/m.
- ENSURE ALL JOINTS ARE FULLY MORTARED.
- MORTAR SHALL BE 1:1:6 (CEMENT; LIME; SAND). MORTAR COLOUR TO MATCH RECONSTITUTED LIMESTONE BLOCKS.

No.	REVISION	BY	DATE	AUTH
2	NEW DESIGN BY SANTILLO ENGINEER	M.V.	8/2007	
3	UPDATED TITLE BLOCK BRAND	D.N.	8/2022	
4	AMENDED PANEL DIMENSION	D.N.	1/2024	L.N.

• ALL EXPOSED SURFACES OF WALL SHALL BE COATED WITH ANTI-GRAFFITI TREATMENT ON COMPLETION OF WORKS.


**COMPACTION REQUIREMENTS**

• COMPACT SUB-GRADE BELOW WALL TO A MINIMUM OF 8 BLOWS PER 300mm TESTED USING A STANDARD PERTH PENETROMETER FOR A DEPTH OF 750mm BELOW THE UNDERSIDE OF WALL.



**DESIGN WIND LOADING**

TERRAIN CATEGORY 1

**SECTION 1**



**SECTION 2**



**ISOMETRIC VIEW**  
DIAGRAMMATIC

\* INDICATES SIGNATURES ON ORIGINAL ISSUE OF DRAWING.

SCALE: 1:20 0 200 400 600 800 1000 SCALE IN MILLIMETRES		DATUM: N/A	GRID: N/A	<b>SIGN</b> PARK SIGN WALL DETAIL PLAN AND SECTIONS  STANDARD	<b>CITY OF WANNEROO</b> <b>ASSETS</b>			
DESIGNED: SANTILLO ENGINEER PTY LTD STRUCTURAL ENGINEER	DESIGN CHECKED:	APPROVED: * B. McCAWLEY COORDINATOR ASSET PLANNING SERVICES 2/9/2022	FILE No. N/A		DRAWING No. TS 06 -5-4	SHEET REVISION		ORIGINAL DRG. SIZE A3
DRAWN: SANTILLO ENGINEER PTY LTD STRUCTURAL ENGINEER	DESIGN ARCHIVE:	APPROVED: * B. CHANG MANAGER ASSET PLANNING 2/9/2022	PROJECT No. N/A					
DRAWING ARCHIVE:	STANDARDS CHECK: * J. SONG TRANSPORT & DRAINAGE ASSET PLANNER 2/9/2022	APPROVED: * H. SINGH DIRECTOR ASSETS 2/9/2022						